



**Home Innovation**  
NGBS GREEN CERTIFIED™

THIS SIGNIFIES THE FOLLOWING CONSTRUCTION PRODUCTS

PANASONIC ENERGY RECOVERY VENTILATOR; INTELLI-BALANCE  
100, FV-10VEC2, FV-10VE2, FV-20VEC1, FV-10VE2H, FV-10VEC2R,  
FV-10VEC2RH


MANUFACTURED BY

**PANASONIC**

ARE CERTIFIED FOR POINTS TOWARD NGBS GREEN CERTIFICATION TO THE ICC 700  
NATIONAL GREEN BUILDING STANDARD, AS DETAILED BELOW.

Wellness

Smart Home

  
Michael Luzier – President & CEO

12-01-2025  
Approval Date

04-30-2026  
Expiration Date

**CERTIFICATE # 394**

This certificate is not a representation, warranty, or guarantee of product performance or certification of code compliance. For details of the product warranty, consult the product manufacturer.



NGBS Green Certificate #NGBSGCP-000394

Product: Panasonic Energy Recovery Ventilator; Intelli-balance 100, FV-10VEC2, FV-10VE2, FV-20VEC1, FV-10VE2H, FV-10VEC2R, FV-10VEC2RH

Manufacturer: Panasonic

The product(s) shown on this report have been independently verified as eligible products for use in achieving points toward project certification under ICC-700 National Green Building Standard. Home Innovation Research Labs authorizes accredited verifiers to award points toward certification without additional documentation when the product(s) is used as noted below.

2020 NATIONAL GREEN BUILDING STANDARD					
PRACTICE #	PRACTICE DESCRIPTION	POTENTIAL POINTS AVAILABLE	ADDITIONAL CONDITIONAL OF USE TO AWARD POINTS	+Wellness	+Smart Home
902.2.1(4)	An energy-recovery ventilator is installed and an explanation of the operation and importance of the ventilation system is included in the homeowner or building owner manual. 8 points available.	8	Mandatory when maximum air infiltration is less than 5ACH50. An explanation of the operation and importance of the ventilation system is included in the building construction and operations manuals.	✓	
902.1.2	Bathroom and/or laundry exhaust fan with an automatic timer and/or humidistat is installed. 5 points awarded for the first device, 2 points for each additional device. 11 points max.	5	None. 5 points; 2 additional for additional device; 11 max.		
706.3(7)	Smart HVAC system(s) is installed. 1 point for 3-5 products from 706.3; 2 points for 6+ products from 706.3.	1	For 1 point, this product and at least 2 other smart appliances are installed. 1 addition point awarded for 6 or more smart appliances.		✓
902.1.6	Ventilation systems are implemented in accordance with the specifications of ASHRAE 62.1. An explanation of the operation and importance of the ventilation system is building owner manual. 3 points available.	3	System is installed in multifamily common areas. System is implemented in accordance with ASHRAE 62.2-2010 Section 4. An explanation of the operation and importance of the ventilation system is included in the operation or homeowner manuals.	✓	
13.107.7	Exhaust systems are in accordance with Chapter 5 of the ICC IMC or ASHRAE 62.1. Mandatory.	Mandatory	System is installed in non-residential space.		
13.107.8.1	Ventilation is provided to non-residential spaces in accordance with Chapter 4 of the ICC IMC or ASHRAE 62.1. Mandatory.	Mandatory	System is installed in non-residential space.		



## GRESB Scoring Potential

GRESB is a framework widely used by commercial and multifamily organizations that measures the ESG (Environmental, Social, and Governance) performance of a company’s real estate portfolio. Certification to the following 2020 NGBS practices indicates that this product potentially contributes to one or more GRESB Indicator(s). For more information, visit [www.ngbs.com/ESG](http://www.ngbs.com/ESG) and [www.GRESB.com](http://www.GRESB.com).

NGBS Green Certificate #394

Product: Panasonic Energy Recovery Ventilator; Intelli-balance 100, FV-10VEC2, FV-10VE2, FV-20VEC1, FV-10VE2H, FV-10VEC2R, FV-10VEC2RH

Manufacturer: Panasonic

Practice #	Practice Description	GRESB Indicator
902.2.1(4)	An energy-recovery ventilator is installed and an explanation of the operation and importance of the ventilation system is included in the homeowner or building owner manual. 8 points available.	DRE1 ESG strategy during development , DSE1 Health and Well-being